

DETAIL ASSOCIATES, INC.
300 GRAND AVENUE
ENGLEWOOD, NJ 07631
(201) 569-6708

CERTIFICATE OF ANALYSIS

CLIENT: Dumont Board of Education
25 Depew Street
Dumont, New Jersey

DATE SAMPLED: 08/17/16
DATE RECEIVED: 08/22/16
DATE ANALYZED: 09/16/16

PROJECT: NJ16-0286A
Grant School, 100 Grant Avenue, Dumont, NJ

POTABLE WATER ANALYSIS – LEAD DETERMINATION

SAMPLE #	LOCATION	RESULTS (ppb)
GR-0817-1L	Hallway 20	None Detected
GR-0817-2L	Hallway 124	None Detected
GR-0817-3L	Hallway 232	None Detected

NEW JERSEY EPA STANDARD (ppb): 15 ppb (parts per billion)
METHODOLOGY: Lead in Water by Furnace AAS (EPA 200.9)

National Testing Laboratories, Inc.

DETAIL ASSOCIATES, INC.
300 GRAND AVENUE
ENGLEWOOD, NJ 07631
(201) 569-6708

CERTIFICATE OF ANALYSIS

CLIENT: Dumont Board of Education
25 Depew Street
Dumont, New Jersey

DATE SAMPLED: 08/17/16
DATE RECEIVED: 08/22/16
DATE ANALYZED: 09/16/16

PROJECT: NJ16-0286B
Honiss School, 31 Depew Street, Dumont, NJ

POTABLE WATER ANALYSIS – LEAD DETERMINATION

SAMPLE #	LOCATION	RESULTS (ppb)
HO-0817-1L	Hallway 101	None Detected
HO-0817-2L	Hallway 114	None Detected
HO-0817-3L	Hallway 107	None Detected
HO-0817-4L	Hallway 128	None Detected
HO-0817-5L	Hallway 133	None Detected
HO-0817-6L	Hallway 145	None Detected
HO-0817-7L	Hallway 245	None Detected

NEW JERSEY EPA STANDARD (ppb): 15 ppb (parts per billion)
METHODOLOGY: Lead in Water by Furnace AAS (EPA 200.9)

National Testing Laboratories, Inc.

DETAIL ASSOCIATES, INC.
300 GRAND AVENUE
ENGLEWOOD, NJ 07631
(201) 569-6708

CERTIFICATE OF ANALYSIS

CLIENT: Dumont Board of Education
25 Depew Street
Dumont, New Jersey

DATE SAMPLED: 08/17/16
DATE RECEIVED: 08/22/16
DATE ANALYZED: 09/16/16

PROJECT: NJ16-0286C
Selzer School, 435 Prospect Avenue, Dumont, NJ

POTABLE WATER ANALYSIS – LEAD DETERMINATION

SAMPLE #	LOCATION	RESULTS (ppb)
SA-0817-1L	Hallway 106	None Detected
SA-0817-2L	Hallway 115	None Detected
SA-0817-3L	Hallway 130	None Detected

NEW JERSEY EPA STANDARD (ppb): 15 ppb (parts per billion)
METHODOLOGY: Lead in Water by Furnace AAS (EPA 200.9)

National Testing Laboratories, Inc.

DETAIL ASSOCIATES, INC.
300 GRAND AVENUE
ENGLEWOOD, NJ 07631
(201) 569-6708

CERTIFICATE OF ANALYSIS

CLIENT: Dumont Board of Education **DATE SAMPLED:** 08/17/16
25 Depew Street **DATE RECEIVED:** 08/22/16
Dumont, New Jersey **DATE ANALYZED:** 09/16/16

PROJECT: NJ16-0286D
Lincoln School, 80 Prospect Avenue, Dumont, NJ

POTABLE WATER ANALYSIS – LEAD DETERMINATION

SAMPLE #	LOCATION	RESULTS (ppb)
LI-0817-1L	Hallway 15	None Detected
LI-0817-2L	Hallway 101	None Detected
LI-0817-3L	Hallway 201	None Detected

NEW JERSEY EPA STANDARD (ppb): 15 ppb (parts per billion)

METHODOLOGY: Lead in Water by Furnace AAS (EPA 200.9)

National Testing Laboratories, Inc.

Lincoln School – 08-17-16
80 Prospect Avenue, Dumont, NJ

DETAIL ASSOCIATES, INC.
300 GRAND AVENUE
ENGLEWOOD, NJ 07631
(201) 569-6708

CERTIFICATE OF ANALYSIS

CLIENT: Dumont Board of Education **DATE SAMPLED:** 08/17/16
25 Depew Street **DATE RECEIVED:** 08/22/16
Dumont, New Jersey **DATE ANALYZED:** 09/19/16

PROJECT: NJ16-0286E
High School, 101 New Milford Ave., Dumont, NJ

POTABLE WATER ANALYSIS – LEAD DETERMINATION

SAMPLE #	LOCATION	RESULTS (ppb)
HS-0817-1L	Gym North	None Detected
HS-0817-2L	Gym South	None Detected
HS-0817-3L	Exit 106	None Detected
HS-0817-4L	Hallway 71	None Detected
HS-0817-5L	Hallway 79	None Detected
HS-0817-6L	Cafeteria Cooler	None Detected
HS-0817-7L	Hallway 216	None Detected
HS-0817-8L	Hallway 227	None Detected
HS-0817-9L	Hallway 304R	None Detected
HS-0817-10L	Hallway 201R	None Detected

NEW JERSEY EPA STANDARD (ppb): 15 ppb (parts per billion)
METHODOLOGY: Lead in Water by Furnace AAS (EPA 200.9)

National Testing Laboratories, Inc.

Dumont High School – 8-17-16
101 New Milford Avenue, Dumont, NJ